



NOTES:

All Sewer Lines Are 150φ uPVC Pipe Class "SN8" Unless Noted Otherwise

All Pipe Joints Are Rubber Ring Type Unless Noted Otherwise

All Bedding To Sewer Is "Type 3" Unless Noted Otherwise

All Trenching Excavated In Soil

Year Of Construction 2017

Each Allotment Is Served By A 100φ uPVC House Connection

We RPS Australia East Pty Ltd, Registered Surveyor – Land hereby certify that the Levels and Dimensions shown hereon are a correct record of our Survey which was performed in accordance with Council Accuracy Standards

..... Authorised Delegate Date

"I, MARK SHAW being a certified / registered engineer and duly authorised representative of KN GROUP PTY LTD hereby -

- × Certify the information contained in this drawing is an accurate "AS CONSTRUCTED" representation of the works.
- × Accept responsibility for the "AS CONSTRUCTED" information contained in this drawing.
- × Acknowledge the "AS CONSTRUCTED" information contained in the drawing may be relied on by Council and others.

Certification for Stage by on

for KN GROUP PTY LTD.
Registered Professional Engineer of Queensland - No. 17544

A1

-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-
JUNE 2017	ORIGINAL ISSUE	RPS	RPS	-	-
INDEX	DATE	DRAWN	CHECKED	PASSED	

DRAWN	RZ/AJH	JUNE 2017
CHECKED	AJH	JUNE 2017
PASSED	-	-
INITIALS	-	DATE



Unitywater
NORTHEAST BUSINESS PARK C/- KN GROUP PTY LTD CONSULTING ENGINEERS
NORTH HARBOUR - STAGE 13A
AS CONSTRUCTED SEWERAGE RETICULATION

SCALE	1:500 at A1
SHEET OF SHEETS	-
DRAWING NO.	-
	-
	-
	20430-192