

- LEGEND**
- ∅ Pipe Diameter
 - Fire Hydrant
 - Temporary Hydrant/End
 - ⊗ Valve
 - ⊕ 11.25° BEND
 - ⊖ 22.5° BEND
 - ⊙ 45° BEND
 - ⊘ 90° BEND
 - ⊙ Ready Tap
 - ⊙ Water Meter
 - C — Water Crossing
 - Water Main
 - DICL Water Main

- NOTES**
- Water main pipes are Ø150 PVC-O Class PN16 unless noted otherwise.
 - All road crossings are Ø150 DICL Class DN35.



ENGINEER'S CERTIFICATION

I, MARK SHAW being a certified / registered engineer and duly authorised representative of KN GROUP PTY LTD hereby:

- Certify the information contained in the drawing is an accurate "AS CONSTRUCTED" representation of the works.
- Accept responsibility for the "AS CONSTRUCTED" information contained in this drawing.
- Acknowledge the "AS CONSTRUCTED" information contained in drawing may be relied on by Council and others.

Certification by _____ on _____


for KN GROUP PTY LTD.
Registered Professional Engineer of Queensland - No. 17544

SURVEYOR'S CERTIFICATION

We T.H. JENSEN BOWERS PTY LTD, hereby certify that the vertical and horizontal locations and dimensions shown on this plan are a true and correct record and were located by survey.

Director _____ Date: 02/10/18

AS CONSTRUCTED



A1	INDEX	DATE	REVISIONS	DRAWN	CHECKED	PASSED	INITIALS	DATE
	A	11/19/18	Original Issue	LB	JM			

DRAWN	LB	11/19/18
CHECKED	JM	15/05/18
PASSED		

JENSEN BOWERS
SURVEYORS PLANNERS DEVELOPMENT ADVISORS
jensenbowers.com.au

72 Costin Street, Fortitude Valley, Qld. 4006
P.O. Box 7390, Spring Hill, Qld. 4004
T: (07) 3852 1771 F: (07) 3252 9818
T.H. Jensen & Bowers Pty. Ltd. (Consulting Surveyors)
ABN: 52 010 872 607
© Copyright reserved to Jensen Bowers Group Consulting Pty Ltd



Unitywater

NORTHEAST BUSINESS PARK C/ - KN GROUP PTY LTD CONSULTING ENGINEERS
NORTH HARBOUR - STAGE 22
AS CONSTRUCTED WATER RETICULATION

SHEET 1 OF 1 SHEETS	SCALE 1:500
REVISION DATE 11/19/18	REVISION A
DISCIPLINE CODE	
DRAWING NO. U-2018-0666	