



**LEGEND**

- ∅ Pipe Diameter
- Fire Hydrant
- Temporary Hydrant/End
- ⊗ Valve
- ① 11.25° BEND
- ② 22.5° BEND
- ③ 45° BEND
- ④ 90° BEND
- ⊕ Ready Tap
- Water Meter
- Water Crossing
- Water Main
- DICL Water Main

**NOTES**

- Water main pipes are Ø150 PVC-0 Class PN16 unless noted otherwise.
- All road crossings are Ø150 DICL Class DN35 unless noted otherwise.



**ENGINEER'S CERTIFICATION**

I, Mark Shaw, of KN GROUP PTY LTD, hereby certify that:  
 1. The information contained in this drawing / document is in compliance with approved drawings and design.  
 2. The new water and sewerage works defined by this drawing have been designed and constructed in accordance with the SEQ Code.  
 3. This represents an accurate record of as-constructed works.  
 4. I accept responsibility for the information contained in this drawing / document.

Mark Shaw  
 RPEQ (signature) RPEQ No. 17544 Date: \_\_\_\_\_


**REGISTERED SURVEYOR'S CERTIFICATION**

We, T.H. JENSEN BOWERS PTY LTD, hereby certify that the vertical and horizontal locations and dimensions shown on this plan are a true and correct record and were located by survey.

Registered Surveyor (sig) \_\_\_\_\_ Reg. Surveyor No. 3756 Date: 29/09/22

**COORDINATE DATUM NOTE:**  
 HORIZONTAL COORDINATES(E,N) SUPPLIED ARE MAPPING GRID OF AUSTRALIA(MGA), ZONE 56 BASED ON THE UNIVERSAL TRANSVERSE MERCATOR PROJECTION AND THE GEOCENTRIC DATUM OF AUSTRALIA 1994.

PSM 724.18  
 E: 498714.197  
 N: 6999186.146  
 RL: 14.859m



**AS CONSTRUCTED**

<b>A1</b>	A 19/08/2022 Original Issue		JB	SJM	DB	PASSED	DB	19/08/2022	<p><b>JENSEN BOWERS</b>        SURVEYORS PLANNERS DEVELOPMENT ADVISORS        jensenbowers.com.au</p>	<p><b>Unitywater</b>        2016009402529        North Harbour Stage 29</p>	SHEET 2 OF 2 SHEETS	SCALE 1:500
	INDEX DATE REVISIONS		DRAWN	CHECKED	PASSED	INITIALS	DATE	REVISION DATE 19-08-2022			REVISION A	
								DISCIPLINE CODE C			DRAWING NO. U-2021-3846	